



Remmers GmbH  
Report No. RE 2310-1468

# Cleanroom<sup>®</sup> Suitable Materials

Epoxy OS Color  
Particle (vs. PA6 Nylon): ISO 1

## FLOORING & COATING

### Single product Particle Emission

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Remmers GmbH**  
Löningen, Germany

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number RE 2310-1468.

The level of particulate contamination emitted during application of tribological stress on the material pairing specified lies within the permissible values of the corresponding Air Cleanliness Class in accordance with ISO 14644-1:

Material pairing and test		Suitable for Air Cleanliness Class (ISO 14644-1)
Epoxy OS Color (light gray)	vs. PA6	ISO Class: 1
Reel-on-disc test; normal force: 300N		

This document only applies to the named product in its original state and is valid for a period of 5 years from the current date the document was issued. The document can be verified under [www.tested-device.com](http://www.tested-device.com).

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

RE 1808-1062  
Report No. first document  
RE 2310-1468  
Report No. current document

Stuttgart, October 29, 2018  
Place, date of first document issued  
Stuttgart, December  
Place, current date

on behalf of   
Dr.-Ing. Udo Gommel, Project Manager Fraunhofer IPA